

施設名：小立野水源 採水場所：豊田第4分団詰所

項目	単位	基準値	2025/04/28	2025/05/19	2025/06/02	2025/07/07	2025/08/04	2025/09/01	2025/10/06	2025/11/10	2025/12/01	2026/01/06	2026/02/02	2026/03/04	測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			上水道	上水道	上水道	上水道	上水道	上水道	上水道	上水道	上水道	上水道	上水道	上水道						
水温	℃	-	19.0	21.0	21.5	27.3	31.8	30.5	26.5	20.0	16.0	12.5	10.8	14.5	12	0	21.0	31.8	10.8	2025/08/04
気温	℃	-	22.9	26.3	24.1	32.2	32.5	32.8	28.7	19.3	16.1	8.3	7.5	13.3	12	0	22.0	32.8	7.5	2025/09/01
残留塩素濃度	mg/L	-	0.3	0.2	0.2	0.3	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3	12	0	0.2	0.3	0.2	2025/04/28
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	0	0	0	0	12	0	0	0	0	---
大腸菌	-	検出されないこと	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	12	0	---	---	---	---
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	0.00015未満	---	---	---	---	---	---	---	---	---	---	1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.0005mg/L以下	---	0.00005未満	---	---	---	---	---	---	---	---	---	---	1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	0.0005未満	---	---	---	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	0.0007	---	---	---	---	---	---	---	---	---	---	1	0	0.0007	0.0007	0.0007	2025/05/19
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	0.0005未満	---	---	---	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	0.002未満	---	---	---	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	0.004未満	---	---	---	---	---	---	---	---	---	---	1	0	0.004未満	0.004未満	0.004未満	---
シアン化合物イオン及び塩化シアン	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	---	0.001未満	---	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	1.3	---	---	---	---	---	---	---	---	---	---	1	0	1.30	1.30	1.30	2025/05/19
フッ素及びその化合物	mg/L	0.8mg/L以下	---	0.05未満	---	---	---	---	---	---	---	---	---	---	1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	0.03	---	---	---	---	---	---	---	---	---	---	1	0	0.03	0.03	0.03	2025/05/19
四塩化炭素	mg/L	0.002mg/L以下	---	0.0002未満	---	---	---	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	0.003未満	---	---	---	---	---	---	---	---	---	---	1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	0.0004未満	---	---	---	---	---	---	---	---	---	---	1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	0.0002未満	---	---	---	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
テトラクロロエチレン	mg/L	0.01mg/L以下	---	0.0002未満	---	---	---	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	0.0002未満	---	---	---	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	0.0002未満	---	---	---	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.6mg/L以下	---	0.06未満	---	---	0.06未満	---	---	0.06未満	---	---	0.06未満	---	4	0	0.06未満	0.06未満	0.06未満	---
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---
クロホルム	mg/L	0.06mg/L以下	---	0.0006	---	---	0.0013	---	---	0.0004	---	---	0.0003	---	4	0	0.0007	0.0013	0.0003	2025/08/04
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---
ジブロモクロロメタン	mg/L	0.1mg/L以下	---	0.0003	---	---	0.0003	---	---	0.0003	---	---	0.0003	---	4	0	0.0003	0.0003	0.0003	---
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	---	0.001未満	---	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---
総トリハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	---	0.01未満	---	---	0.01未満	---	---	0.01未満	---	4	0	0.01未満	0.01未満	0.01未満	---
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---
ブロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0003	---	---	0.0005	---	---	0.0003	---	---	0.0003	---	4	0	0.0004	0.0005	0.0003	2025/08/04
ブロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	---	0.0002未満	---	---	0.0002未満	---	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	---	0.004未満	---	---	0.004未満	---	---	0.004未満	---	4	0	0.004未満	0.004未満	0.004未満	---
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	0.004	---	---	---	---	---	---	---	---	---	---	1	0	0.004	0.004	0.004	2025/05/19
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	0.006	---	---	---	---	---	---	---	---	---	---	1	0	0.006	0.006	0.006	2025/05/19
鉄及びその化合物	mg/L	0.3mg/L以下	---	0.02未満	---	---	---	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	0.029	---	---	---	---	---	---	---	---	---	---	1	0	0.029	0.029	0.029	2025/05/19
ナトリウム及びその化合物	mg/L	200mg/L以下	---	5.8	---	---	---	---	---	---	---	---	---	---	1	0	5.8	5.8	5.8	2025/05/19
マンガン及びその化合物	mg/L	0.05mg/L以下	---	0.001未満	---	---	---	---	---	---	---	---	---	---	1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	6.1	5.8	5.8	6.2	5.9	5.8	5.5	5.7	5.8	5.9	6.3	6.0	12	0	5.9	6.3	5.5	2026/02/02
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	65	---	---	65	---	---	69	---	---	67	---	4	0	67	69	65	2025/11/10
蒸発残留物	mg/L	500mg/L以下	---	110	---	---	100	---	---	110	---	---	110	---	4	0	108	110	100	2025/05/19
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	0.02未満	---	---	---	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	0.000001未満	---	---	---	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソボルネオール	mg/L	0.00001mg/L以下	---	0.000001未満	---	---	---	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	0.002未満	---	---	---	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	0.0005未満	---	---	---	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	12	0	0.2未満	0.2未満	0.2未満	---
pH値	-	5.8以上8.6以下	7.6	7.7	7.7	7.7	7.7	7.6	7.7	7.7	7.6	7.7	7.7	7.7	12	0	7.7	7.7	7.6	2025/05/19
味	-	異常でないこと	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	12	0	---	---	---	---
臭気	-	異常でないこと	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	12	0	---	---	---	---
色度	度	5度以下	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	12	0	0.5未満	0.5未満	0.5未満	---
濁度	度	2度以下	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	12	0	0.1未満	0.1未満	0.1未満	---
上記項目についての水質基準適合判定			適合	適合	適合	適合	適合	適合	適合	適合	適合	適合	適合	適合						